

Hazard Checklist

Fire Extinguisher Safety

Hazard		Satisfactory	Needs Attention	Not Applicable	Target Date for Completion	Date Completed
1	Has the fire extinguisher been checked for any physical damage such as corrosion or rust?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
2	Has the nozzle been checked to ensure it is not clogged and does not have any leaks?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
3	Is the pressure gauge or indicator on the unit in the operable (green) range ?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
4	Is a person who is licensed by a professional fire protection company performing annual inspections of your fire extinguishers and placing new annual service tags on your extinguishers?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
5	Are you inspecting, performing maintenance, and testing all fire extinguishers in accordance with Cal/OSHA regulations ?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
6	Does the service tag on the extinguisher show that it has been inspected on a monthly basis?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
7	Is there a clear path to access all fire extinguishers?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
8	Are the fire extinguishers at a height where they can be accessed by fully mobile and non-mobile personnel such as those in wheelchairs?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
9	Is the extinguisher labeled with a sign so that is easy to see? NOTE: All fire extinguishers need to be clearly labeled with a "FIRE EXTINGUISHER" label placed above it so that the location of the fire extinguisher is clearly defined.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
10	Is the locking pin and the tamper seal firmly in place?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
11	Is the fire extinguisher in a location where it will not be subjected to physical damage or some other type of blunt force damage?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
12	Have you ensured that the travel distance for fire extinguishers used for Class A fires is no more than 75 feet away from each other (Cal/OSHA 6151)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
13	Have you ensured that all fire extinguishers used for Class B fires are no more than 50 feet from the Class B fire hazard area (Cal/OSHA 6151)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
14	Are D rated fire extinguishers that require a hydrostatic test being tested once every 5 to 12 years by a trained professional?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
15	Have all employees been trained on the general principles of fire extinguisher use and the hazards associated with using a fire extinguisher?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
16	Are all employees provided with fire extinguisher training when first hired and then annually thereafter?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
17	Are employees aware of the P.A.S.S. method so they understand how to use a fire extinguisher effectively?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
18	Do employees understand what Class A, B C, D and K rated extinguishers are used for?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		

Hazard

		Satisfactory	Needs Attention	Not Applicable	Target Date for Completion	Date Completed
19	Are the operating instructions on the nameplate legible and facing outward?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
20	Is all training documented and are training records retained?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
21		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		

Name of evaluator _____

Date _____

Actions Taken to Correct Items Checked as "Needs Attention"

Hazard #	
Hazard #	
Hazard #	
Hazard #	
Hazard #	

The above evaluations and/or recommendations are for general guidance only and should not be relied upon for medical advice or legal compliance purposes. They are based solely on the information provided to us and relate only to those conditions specifically discussed. We do not make any warranty, expressed or implied, that your workplace is safe or healthful or that it complies with all laws, regulations or standards.

For more information, visit: www.SafeAtWorkCA.com